

TEST REPORT

No. 13978 010 A

English version - original in french

ISSUED TO:

FRANKLIN FRANCE

BP 106

13, rue Louis Armand

77834 OZOIR LA FERRIERE CEDEX - FRANCE

SUBJECT:

LIGHTNING CURRENT SHOCK WAVE TESTS ON THREE OVERVOLTAGE COUNTERS MANUFACTURED BY FRANKLIN FRANCE

Date of tests:

September 7th and 8th, 1999.

This document is composed of two pages.

Fontenay-aux-Roses, October 10, 1999

Testing Manager: Régis VIDAL

Technical Manager,



This document may only be reproduced in full, by means of photographic facsimile. Any partial reproduction and any insertion of the test results in an accompanying document with a view to publication is subject to LCIE's prior approval. This document results from tests carried out on a specimen, a sample or a test piece. It does not prove the conformity of the totality of the manufactured products with the tested item. The LCIE's liability applies only to the French version

AGr - GB

LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES

Société anonyme à Directoire et Conseil de surveillance au capital de 103 592 000 Francs - RCS Nanterre B 408 363 174

Siège social : 33, avenue du Général Leclerc - F 92260 Fontenay-aux-Roses - Tél. : +33 (0)1 40 95 60 60

1 - TESTED ITEM

The tests were performed on three overvoltage counters manufactured by FRANKLIN FRANCE with the following inscriptions:

Ordering reference: AFV 0908 CS
Display: 00 to 99

Detection threshold for a 8/20 μ s wave shape (minimum discharge current detected): 150 A
Maximum discharge current detected: 60 kA for a 8/20 μ s wave shape (90 kA for 4/10 μ s)

2 - TESTS PERFORMED

The tests performed were lightning shock wave tests with a lightning wave shape of 8/20 μ s.

3 - DATE OF TESTS

The tests were performed at LCIE Laboratories on the 7th and 8th of September 1999, in the presence of a member of the FRANKLIN FRANCE company and according to his instructions.

4 - APPLICATION MODE OF THE SHOCK WAVES AND TEST RESULTS

For each counter, 8/20 μ s shaped lightning current shock waves (in conformity with the recommendations of IEC 60.1 publication of 1989) of variable amplitude from 150 A to 78 kA were applied with either polarity between the input and output conductors.

No anomaly was observed during these tests.

The counting of the number of lightning shock waves applied was identical to the number of generated shock waves.

5 - CONCLUSION

The test results are in conformity with the specifications listed in the manufacturer's data sheet.
